



NOTES:

1. BACKFLOW PREVENTER(S) FOR WATER FIRE SPRINKLER SYSTEMS SHALL BE:
 - A) 3/4 INCH TO 2 INCH = WATTS 007QT (ASSE 1015) OR COUNTY APPROVED EQUAL
 - B) 2 1/2 INCH AND ABOVE = WATTS 709 ONSY (ASSE 1015) OR COUNTY APPROVED EQUAL.
2. INSTALL A DRAIN FOR THE BACKFLOW PREVENTER(S).
3. BACKFLOW PREVENTER(S) FOR IRRIGATION SYSTEMS SHALL BE:
 - A) 1/2 INCH - 3 INCH = WATTS 009QT (ASSE 1013) OR COUNTY APPROVED EQUAL.
 - B) 3 1/2 INCH AND ABOVE = WATTS 909QT (ASSE 1013) OR COUNTY APPROVED EQUAL.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 6/29/95
 DIRECTOR OF DEVELOPMENT SERVICES DATE
[Signature] 6/29/95
 WATER / SEWER ENGINEER DATE

STANDARD DETAIL

SPRINKLER & DOMESTIC
 SYSTEM CONNECTION
 (COMMERCIAL/INDUSTRIAL)

REVISIONS:

W
 1.01