



NOTES:

1. SETTER TO BE PLACED IN PIT THAT IS 30" IN DIAMETER OR LARGER, SEE DETAIL W6.16.
2. ELECTRONIC METER READING COVER WITH REMOVABLE PLUG. MANUFACTURER FORD OR COUNTY APPROVED EQUAL.
3. METER SETTING SHOULD NOT BE INSTALLED IN DRIVEWAY, SIDEWALK, OR PAVED/CONCRETE AREAS.
4. DUAL CHECK VALVE WILL BE INSTALLED AS SPECIFIED UNDER UTILITY PERMIT AND MUST BE STAMPED ASSE 1024.
5. IF FIRE SPRINKLER SYSTEM IS NOT A STANDARD DOMESTIC WATER FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH CROSS CONNECTION CONTROL BILL 2005-20, AN ASSE 1013 REDUCED PRESSURE ZONE BACKFLOW ASSEMBLY IS REQUIRED.
6. USE METER YOKE FORD #Y-502 (5/8" METER), 503 (3/4" METER), OR 504 (1" METER) AS SPECIFIED.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 1-18-07
CHIEF OF DEVELOPMENT SERVICES DATE

[Signature] 1-18-07
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

INGROUND METER SETTING

HOMES WITH FIRE
SPRINKLER SYSTEMS

- 5/8", 3/4", & 1" METER
- 1-1/2" FIRE SPRINKLER LINE

REVISIONS:

W
6.14